
The original instrument and the following digest, which constitutes no part of the legislative instrument, were prepared by Christopher D. Adams.

DIGEST

Morrell (SB 75)

Proposed law provides the Department of Health and Hospitals, office of public health, shall promulgate rules and regulations pursuant to the Administrative Procedure Act that require a public water system to maintain a minimum disinfectant level that is more than a trace of free or total chlorine in the water being delivered to the distribution system, in finished water storage tanks, and in all points of the distribution.

Proposed law provides the department shall submit an annual report to the legislative health and welfare committees, no later than February 1st of each year.

Effective August 1, 2014.

(Adds R.S. 40:4.15)